

OHIO TURNPIKE AND INFRASTRUCTURE COMMISSION

ADDENDUM NO. 7 ISSUED: June 1, 2023

PROJECT NO. 43-23-04

BRIDGE REPLACEMENT OHIO TURNPIKE OVER TINKERS CREEK M.P. 185.6 SUMMIT & PORTAGE COUNTIES, OHIO

ISSUED APRIL 13, 2023

OPENING DATE: 2:00 P.M. (EASTERN TIME) MAY 11 18 25 JUNE 1-6, 2023

ATTENTION OF BIDDERS IS DIRECTED TO:

ANSWERS TO QUESTIONS RECEIVED THROUGH 5:00 P.M. ON MAY 31, 2023

MODIFICATIONS TO THE CONTRACT DOCUMENTS

Issued by the Ohio Turnpike and Infrastructure Commission through Aimee W. Lane, Esq., Director of Contracts Administration.

Aimee W. Lane, Esq.,

Director of Contracts Administration

Gimee W. Lare

June 1, 2023

Date

ANSWERS TO QUESTIONS RECEIVED THROUGH 5:00 P.M. ON MAY 31, 2023:

- Q#90 Shouldn't the portable concrete barrier wall that is on the structure separating eastbound and westbound traffic in phases 2 and 3 be bridge mounted?
- A#90 Per ODOT Design Data Sheet PCBDD, anchors are not required for PCB unless there is a drop off behind barrier placement. More than 6-ft is provided behind the barrier in Phases 2 and 3 so no drop off is present. For bi-directional traffic the barrier will deflect based on estimations given in the ODOT Design Data Sheet PCBDD, but the deflection can be accommodated given the proposed plan shoulder and lane widths.
- Q#91 A general contractor approached my company to provide a ground improvement solution for the poor soil conditions for the Bridge Replacement Ohio Turnpike Over Tinkers Creek M.P. 185.6 Project. We received Addendum 6, which includes the updated requirements for ground improvement requirements since the base bid was opened up to additional ground improvement techniques. The general contractor directed me to reach out to this email with any pre-bid questions. I am requesting an extension to provide sufficient time to review and implement all the updated requirements in Addendum 6.
- A#91 OTIC will not extend the bid date and time. The bid date and time is June 6, 2023, at 2:00pm.

END OF ADDENDUM NO. 7