**OHIO TURNPIKE AND**
**INFRASTRUCTURE COMMISSION**

**ADDENDUM NO. 4**
**ISSUED MAY 18, 2020**

**PROJECT NO. 58-20-01**

**NEW MAINLINE TOLL PLAZA FACILITY**
**UTILITY BUILDINGS, TOLL BOOTHS & CANOPIES**
**MILEPOST 49**
**LUCAS COUNTY, OHIO**

**OPENING DATE: 2:30 ~~2:00~~ P.M. (EASTERN TIME), MAY 27 ~~21~~, 2020**

**ALL BIDS MUST BE ELECTRONICALLY SUBMITTED**

**ATTENTION OF BIDDERS IS DIRECTED TO:**
**ANSWERS TO QUESTIONS RECEIVED THROUGH 12:00 P.M. ON MAY 18, 2020**

**MODIFICATIONS TO THE CONTRACT DOCUMENTS**

Plan Sheets: E102, I113 and I116
-AND-
Specification Section: 323413
-AND-
Approved Equals: 284621.11
-AND-
EXTENSION OF THE BID OPENING TO 2:30 PM ON MAY 27, 2020

Issued by the Ohio Turnpike and Infrastructure Commission through Jennifer L. Stueber, Esq., General Counsel.

May 18, 2020
Date

Jennifer L. Stueber, Esq.,
General Counsel

**ANSWERS TO QUESTIONS RECEIVED THROUGH 12:00 P.M. ON MAY 18, 2020:**

**Q#68 Page SP-1245 of the contract documents specifies 4 manufacturers for the pedestrian bridge. However, the notes on plan sheet B103 state that the fabricator has to be prequalified with ODOT as a Level 6 fabricator. This eliminates 2 out of the 4 specified manufacturers. Can this requirement be removed, and/or can the field be opened up to all ODOT Level 6 pedestrian bridge producers?**

*A#68 This Addendum No. 4 revises the Specification Section 323413, Article 2.01 Manufacturers, to remove the requirements to use the four manufacturers listed. All manufacturers shall be prequalified through ODOT's Office of Materials Management as a Level 6 Fabricator as well as meeting all the requirements of the Plans and Specifications.*

**Q#70 Please find the attached substitution form for a Siemens fire alarm system for the above mentioned project.**

*A#70 The proposed approved equals have been reviewed and the approval/disapproval action is included in the APPROVED EQUALS CHART below.*

**Q#71 The reader pole details on drawing I116 show galvanized plates and brackets, are these being provided by the 39-20-02 contractor?**

*A#71 This Addendum No. 4 revises the Plan Sheet I116 to clarify the scope of work.*

**Q#72 On drawing E102 Note 6 it states the 39-20-02 is to provide and install the pole, are they also providing the brackets?**

*A#72 This Addendum No. 4 revises the Plan Sheet E102, Note 6 to clarify the scope of work.*

**Q#73 Who is to furnish and install the phone support plates on drawing I113?**

*A#73 This Addendum No. 4 revises the Plan Sheet I113 to clarify the scope of work.*

**Q#74 With all of the recent changes and additions to the E & I drawings has anyone proposed a bid extension?**

*A#74 This Addendum No. 4 revises the Bid Opening date to 2:30 P.M. (EASTERN TIME), MAY 27, 2020.*

**APPROVED EQUALS CHART:**

The following are modifications to the Approved Equals Chart for this Project with the issuance of Addendum No. 4:

| COMPANY NAME | PRODUCT | SPECIFICATION | APPROVAL | Addendum |
|---|---|---|---|---|
| Scranton Products | Hiney Hiders Partitions | 102113.17 | Approved | 1 |
| Scranton Products | Duralife Lockers | 105113 | Not Approved | 1 |
| Stanley Commercial Hardware | Door Closer | 087100 | Approved | 1 |
| Stanley Commercial Hardware | Locks | 087100 | Approved | 1 |
| Control Systems of Ohio | Direct Digital Control System | 230923 | Not Approved | 2 |
| Transtar Electric/ Siemens | Fire Alarm | 284621.11 | Approved | 4 |

**Changes to the Specifications:** Deletions are shown with ~~strikethrough~~ text.
Changes / Additions are shown with ***bold italicized*** text.

**Changes to the Drawings:** Additions and deletions are indicated with a cloud and revision triangle thus:

**Receipt of Addendum No. 4**
**Project No. 58-20-01 is hereby acknowledged:**

(Firm Name) _____

(Signature) _____

(Printed Name) _____

(Date) _____

**BIDDERS MUST RETURN THE ABOVE ACKNOWLEDGEMENT OF RECEIPT OF ADDENDUM NO. 4 WITH THEIR BID.**