OHIO TURNPIKE AND
INFRASTRUCTURE COMMISSION

ADDENDUM NO. 4
ISSUED: JUNE 2, 2023

PROJECT NO. 99-22-04

BRIDGE REPAIR BEARD ROAD (C.R. 167) OVER OHIO TURNPIKE M.P. 236.7, MAHONING COUNTY, OHIO

ISSUED MAY 15, 2023

OPENING DATE: 2:00 P.M. (EASTERN TIME) JUNE ~~2~~ 9, 2023

ATTENTION OF BIDDERS IS DIRECTED TO:

ANSWERS TO QUESTIONS RECEIVED THROUGH 5:00 P.M. ON JUNE 1, 2023

MODIFICATIONS TO THE CONTRACT DOCUMENTS

ODOT Standard Drawing MT-95.45 Dated 1-17-2020

-AND-

Special Provision: SP 103

EXTENSION OF THE BID OPENING TO 2:00 PM ON JUNE 9, 2023

Issued by the Ohio Turnpike and Infrastructure Commission through Aimee W. Lane, Esq., Director of Contracts Administration.

Aimee W. Lane

Aimee W. Lane, Esq.,
Director of Contracts Administration

June 2, 2023
Date

ANSWERS TO QUESTIONS RECEIVED THROUGH 5:00 P.M. ON JUNE 1, 2023:

Q#9 Addendum 3 tells the contractor that temporary barrier is to be placed under item SP 202. A shoulder closure will be required with barrier to protect the shore tower. There does not appear to be a TC standard drawing for a shoulder closure or a shoulder closure with barrier wall. Please provide how this traffic is to be accomplished and how much barrier, tapers, signage is required.

A#9 Should a shoulder closure be required with portable concrete barrier, contractor shall use ODOT Standard Construction Drawing MT-95.45. The standard construction drawing provides detailed information to calculate materials necessary for a shoulder closure. ODOT Standard Construction Drawing MT-95.45 is being provided as part of this Addendum.

Q#10 Ref 39 Damage Assessment is not listed in the estimated quantities for Part B on sheet 10/19, nor is it discussed in the Part B plans?

A#10 To be answered in a future addendum.

Q#11 Ref 40 Item 849 Surface Preparation, why is this item listed in Part B as there is no heat straightening.

A#11 To be answered in a future addendum.

END OF ADDENDUM NO. 4