



**OHIO TURNPIKE AND  
INFRASTRUCTURE COMMISSION**

**ADDENDUM NO. 2**  
**ISSUED MAY 20, 2020**

**PROJECT NO. 59-20-04**  
**PART A: REPAIRS AND RESURFACING**  
**EASTBOUND & WESTBOUND ROADWAYS**  
**MILEPOST 209.6 TO MILEPOST 216.1**  
**PART B: REPAIRS AND RESURFACING**  
**INTERCHANGE 218**  
**MILEPOST 218.7**  
**TRUMBULL AND MAHONING COUNTIES, OHIO**

**OPENING DATE: 2:00 P.M. (EASTERN TIME), MAY 27, 2020**

**ATTENTION OF BIDDERS IS DIRECTED TO:**  
**ANSWERS TO QUESTIONS RECEIVED THROUGH 2:00 PM ON MAY 20, 2020**

Issued by the Ohio Turnpike and Infrastructure Commission through Jennifer L. Stueber, Esq., General Counsel.

Jennifer L. Stueber, Esq.,  
General Counsel

May 20, 2020  
Date

**ANSWERS TO QUESTIONS RECEIVED THROUGH 2:00 P.M. ON MAY 20, 2020:**

**Q#2** The as per plan note for Full depth Pavement Repair states to use SP 404 for the top 2". Which type of SP 404 will be acceptable?

*A#2 The Contractor shall used SP 404, Asphalt Concrete Surface Course, Using Crushed Slag, PG 76-22 (FR) for the top 2" for the full depth pavement repairs.*

**Receipt of Addendum No. 2**

**Project No. 59-20-04 is hereby acknowledged:**

(Firm Name) \_\_\_\_\_

(Signature) \_\_\_\_\_

(Printed Name) \_\_\_\_\_

(Date) \_\_\_\_\_

**BIDDERS MUST RETURN THE ABOVE ACKNOWLEDGEMENT  
OF RECEIPT OF ADDENDUM NO. 2 WITH THEIR BID.**