

OHIO TURNPIKE COMMISSION

682 Prospect Street
Berea, Ohio 44017

CONSTRUCTION ADMINISTRATION AND INSPECTION SERVICES

**Ref: Exits 52 & 64 Toll Plaza Facility Improvements and Expansion,
Lucas and Wood Counties, Ohio**

PROJECT NO. 71-07-06

**ANSWERS TO QUESTIONS RECEIVED THROUGH
END OF INQUIRY PERIOD, June 28, 2007**

Q#1 Has a construction budget been developed for the project? If so, how much has been budgeted?

A#1 No.

Q#2 What year is the construction anticipated to be implemented?

A#2 2008.

Q#3 Is the intended HVAC “ducted remote system” to be fed from overhead?

A#3 Yes.

Q#4 Will the Toll Booths need to be physically modified and insulated to accept cooling and still operate efficiently? Are they cooled at all now?

A#4 *Modifications will likely be required to physically install ducts, diffusers etc. No additional insulation is required. These toll booths are not cooled at this time.*

Q#5 Is the “remote building” meant for the relocated generator an existing building, or will it be a new building?

A#5 *It will be a new building.*

Q#6 Are new electrical improvements required for the (1) new entrance lane as associated work? For example are electrically operated gates or sensors intended?

A#6 Yes.