

**OHIO TURNPIKE AND
INFRASTRUCTURE COMMISSION**

ADDENDUM NO. 1

PROJECT NOS. 53-17-02 & 53-17-03 (RE-BID)
FUEL PIPING AND CONTAINMENT REPLACEMENT PROJECT
PORTAGE SERVICE PLAZA (53-17-02)
BRADY'S LEAP SERVICE PLAZA (53-17-03)
MILEPOST 197.0
PORTAGE COUNTY, OHIO

OPENING DATE: 2:00 P.M. (EASTERN TIME), DECEMBER 28, 2016

ALL BIDS MUST BE ELECTRONICALLY SUBMITTED THROUGH BID EXPRESS

ATTENTION OF BIDDERS IS DIRECTED TO:

QUESTIONS AND ANSWERS THROUGH 3:00 PM ON DECEMBER 16, 2016

Issued by the Ohio Turnpike and Infrastructure Commission on December 16, 2016. Issuance authorized by Anthony D. Yacobucci, Chief Engineer, and Mark R. Musson, Director of Contracts Administration.


Anthony D. Yacobucci Date


Mark R. Musson Date

**OHIO TURNPIKE AND INFRASTRUCTURE COMMISSION
ADDENDUM NO. 1
PROJECT NOS. 53-17-02 & 53-17-03 (RE-BID)**

QUESTIONS AND ANSWERS THROUGH 3:00PM ON DECEMBER 16, 2016

Q#1 Can you better explain what will be required if all of the excavated backfill material is discovered to be clean but cannot be re-used as backfill for the underground storage tanks?

A#1 All excavated material will be tested in accordance with BUSTR and OAC standards to determine if the soil is Petroleum Contaminated Soil ("PCS"). Any excavated material that meets BUSTR and OAC reuse requirements, and meets any additional requirements outlined in the Contract Documents may be reused as backfill and/or placed onsite in accordance with the Contract Documents.

*If the Contractor does not reuse the approved excavated material as backfill, any excavated material that meets BUSTR and OAC requirements for on-site re-use shall be permanently placed in the designated 'On-Site Soil Storage' on Plan Sheet F1.2 by loading, transporting, spreading, grading, compacting, seeding and mulching or disposed of offsite in accordance with SP 105 – Disposal of Excess Materials and any applicable regulatory requirements. However, Bid Ref. Item Nos. 3, 4, 5, 6, 11, 12, 13 and 14 will **ONLY** be paid if PCS, as defined by BUSTR and OAC standards, is encountered. If **ALL** excavated materials are not classified as PCS per BUSTR and OAC standards, no payment will be made to the Contractor for Bid Ref. Item Nos. 3, 4, 5, 6, 11, 12, 13 and 14.*

Addendum No. 1 to Contract 53-17-02
& 53-17-03 (RE-BID):

(Firm Name)

(Signature)

(Printed Name)

Date: _____