

OHIO TURNPIKE AND  
INFRASTRUCTURE COMMISSION

ADDENDUM NO. 3

PROJECT NO. 43-17-03  
BRIDGE DECK REPAIR AND REHABILITATION  
ARLINGTON ROAD OVER OHIO TURNPIKE M.P. 122.3,  
JOPPA ROAD OVER OHIO TURNPIKE M.P. 128.5,  
DEAN ROAD OVER OHIO TURNPIKE M.P. 132.4,  
WEST RIVER ROAD OVER OHIO TURNPIKE M.P. 145.8,  
ERIE AND LORAIN COUNTIES, OHIO


OPENING DATE PREVIOUSLY EXTENDED TO:  
2:00 P.M. (EASTERN TIME), ~~DECEMBER 27, 2016~~ JANUARY 4, 2017


ALL BIDS MUST BE ELECTRONICALLY SUBMITTED THROUGH BID EXPRESS

ATTENTION OF BIDDERS IS DIRECTED TO:

QUESTIONS AND ANSWERS THROUGH 10:00 AM ON DECEMBER 21, 2016  
-AND-  
MODIFICATIONS TO THE NOTICE AND COVER PAGE EXTENDING THE OPENING DATE

Issued by the Ohio Turnpike and Infrastructure Commission on December 21, 2016. Issuance authorized by Anthony D. Yacobucci, Chief Engineer, and Mark R. Musson, Director of Contracts Administration.

  
Anthony D. Yacobucci      Date 12/21/16

      12/21/16  
Mark R. Musson      Date

**OHIO TURNPIKE AND INFRASTRUCTURE COMMISSION  
ADDENDUM NO. 3  
PROJECT NO. 43-17-03**

**QUESTIONS AND ANSWERS THROUGH 10:00AM ON DECEMBER 21, 2016**

**Q#11** Addendum 2 has extended the bid date to 12/27/16. Given that a lot of companies (including subcontractors and vendors) will be observing Monday 12/26 as a holiday being Christmas is on a Sunday, will the Turnpike please consider delaying this bid until after the New Year?

*A#11 Yes, the Commission extends the Bid Opening to January 4, 2017 through this Addendum No. 3.*

**Q#12** The addendum 2 bid delay until December 27, 2016 presents problems with getting subcontract and material quotations due to the close proximity to December 26, 2016 which is the observed day off for Christmas. Please push the bid opening to December 28<sup>th</sup> or better yet to January 4<sup>th</sup> to avoid the holidays altogether.

*A#12 Please see the response to Q#11.*

**Q#13** I don't see in section 511B that the maximum concrete temperature prior to placement is specified. Please confirm 95 degrees is the acceptable maximum temperature as indicated in ODOT CMS 511.07.

*A#13 Except to the extent SP 511B, or any other Special Provision, modifies ODOT's 2016 CMS, the applicable provision in the CMS Specification shall govern. Since there are no revisions or differing provisions related to temperature of the concrete material contained in SP 511B, the Specification in CMS 511.07 providing, "Until discharged in the work, ensure that the temperature of all concrete does not exceed 95 °F (35 °C)" shall apply.*

The following changes are made to the Contract Documents for Contract No. 43-17-03:

The Notice to Bidders and Cover Page are modified to extend the bid opening date one week from 2:00PM on ~~December 27, 2016~~ **January 4, 2017**.

Addendum No. 3 to Contract 43-17-03:

\_\_\_\_\_  
(Firm Name)

\_\_\_\_\_  
(Signature)

\_\_\_\_\_  
(Printed Name)

Date: \_\_\_\_\_