

**OHIO TURNPIKE AND
INFRASTRUCTURE COMMISSION**

Q&A NO. 1

PROJECT NO. 56-15-08

**FOR DESIGNING, FURNISHING AND INSTALLING A STEEL
BUILDING AT THE HIRAM MAINTENANCE FACILITY**

OPENING DATE: 2:00 P.M. (EASTERN), SEPTEMBER 15, 2015

ALL BIDS MUST BE SUBMITTED ELECTRONICALLY

ATTENTION OF BIDDERS IS DIRECTED TO:

**ANSWERS TO QUESTIONS RECEIVED
THROUGH 12:00 P.M. SEPTEMBER 10, 2015**

**OHIO TURNPIKE AND INFRASTRUCTURE COMMISSION
ADDENDUM NO. 1
PROJECT NO. 56-15-08**

ANSWERS TO QUESTIONS RECEIVED THROUGH 12:00 P.M., September 10, 2015

- Q#1** Could you provide an interpretation/clarification for the note at the bottom of Page SP-1 which reads “Owner will grade and compact the subgrade to within 12 inches of finished floor elevation”. Is this for entire area of new building and does it include removal and replacement of any existing soils?
- A#1 For the floor slab, the Commission will grade and compact the subgrade to at least 12 inches of the finished floor elevation for the entire building area. The Commission will remove deleterious materials not usable in the floor slab subgrade within the limits of the 12 inches. However, the Commission’s assistance does not include performing any modifications to the soils required for the foundation, which is the responsibility of the Contractor.*

Q&A No. 1 for Contract 56-15-08 is hereby acknowledged:

(Firm Name)

(Signature)

(Printed Name)

Date: _____