

OHIO TURNPIKE AND
INFRASTRUCTURE COMMISSION

ADDENDUM NO. 1

CONTRACT NO. 43-14-03

BRIDGE REPAIRS
OHIO TURNPIKE RAMP OVER S.R. – M.P. 187.0
PORTAGE COUNTY, OHIO

OPENING DATE: 2:00 P.M. (E.D.T.), MARCH 12, 2014

ATTENTION OF BIDDERS IS DIRECTED TO:

ANSWERS TO QUESTIONS RECEIVED THROUGH 12:00 P.M. MARCH 7, 2014

Issued by the Ohio Turnpike and Infrastructure Commission on March 7, 2014. Issuance authorized by Robin Carlin, Deputy Executive Director, and Tommie Jo Marsillio, Director of Contracts Administration.


Robin Carlin 3/7/14
Date


Tommie Jo Marsillio 3/7/14
Date

**OHIO TURNPIKE AND INFRASTRUCTURE COMMISSION
ADDENDUM NO. 1
CONTRACT NO. 43-14-03**

ANSWERS TO QUESTIONS RECEIVED THROUGH 12:00 P.M., MARCH 7, 2014

Q#1 Due to the small quantity and nature of the repair, we request the Ref. No. 6 be changed From: 513 STRUCTURAL STEEL MEMBERS, LEVEL 1, AS PER PLAN; To: 513 STRUCTURAL STEEL MEMBERS, LEVEL UF, AS PER PLAN. This is typical for these projects. The purpose of the change is to reduce costs.

A#1 The suggested change is acceptable.

Q#2 Please Clarify: Considering the damage and repairs shown on the plans for this project, the Turnpike ramp traffic on the bridge will not likely need to be restricted. Drawing MT-97.10 was provided in the plans. Is closing a lane of the Turnpike ramp utilizing a flagger zone a requirement or provided if-needed as determined by the contractor?

A#2 ODOT Standard Drawing is included in the bidding documents in case the Contractor requires closing a lane on the Ohio Turnpike Ramp over State Route 14 but it is not a requirement to close a lane on the ramp.

Q#3 I found no mention of painting the structure after the repairs are complete besides on the traffic permit in appendix B. Not bid items were provided to clarify which Does the Turnpike Commission intend to have the bridge painted after the steel repairs are made as part of this project? If painting is to be included, please provide clarification to the limits of painting, whether the repair 2 coat or 3 coat system or full OZEU will be required. If my request isn't clear, I can provide past project examples.

A#3 The painting of the structure will be performed under a contract bid separately. There is no painting included in this contract.

Addendum No. 1 to is hereby acknowledged:
Contract No. 43-14-03

(Firm Name)

(Signature)

(Printed Name)

Date: _____