

OHIO TURNPIKE AND
INFRASTRUCTURE COMMISSION

ADDENDUM NO. 1

CONTRACT NO. 56-14-01

AMHERST MAINTENANCE BUILDING PAVEMENT IMPROVEMENTS
MILEPOST 141.0, EASTBOUND
LORAIN COUNTY, OHIO

OPENING DATE: 2:00 P.M. (E.D.T), JUNE 27, 2014

ATTENTION OF BIDDERS IS DIRECTED TO:

ANSWERS TO QUESTIONS RECEIVED THROUGH 12:00 P.M. JUNE 24, 2014

Issued by the Ohio Turnpike and Infrastructure Commission on June 24, 2014. Issuance authorized by Richard A. Hodges, Executive Director, and Tommie Jo Marsilio, Director, Contracts Administration.


Richard A. Hodges
Date 6/24/14


Tommie Jo Marsilio
Date 6/24/14

**OHIO TURNPIKE AND INFRASTRUCTURE COMMISSION
ADDENDUM NO. 1
CONTRACT NO. 56-14-01**

ANSWERS TO QUESTIONS RECEIVED THROUGH 12:00 P.M., JUNE 24, 2014

Q#1 Do the existing pipe and structure removals require lsm backfill?

A#1 Yes, the backfill material for the removed structure and removed piping will require Low Strength Mortar (LSM) Backfill. Additionally, LSM will be required for the 12" Conduit that is to be installed under pavement. The LSM material is to be provided in accordance with ODOT Item 613, Low Strength Mortar Backfill (Type 1). The cost for installing this material shall be considered incidental to the cost of the applicable Bid Item and is the responsibility of the Contractor.

Addendum No. 1 to is hereby acknowledged:
Contract No. 56-14-01

(Firm Name)

(Signature)

(Printed Name)

Date: _____