

**OHIO TURNPIKE AND
INFRASTRUCTURE COMMISSION**

ADDENDUM NO. 1

PROJECT NO. 59-15-02

**REPAIRS AND RESURFACING
EASTBOUND AND WESTBOUND ROADWAYS
MILEPOST 72.00 TO MILEPOST 86.20
WOOD, OTTAWA, AND SANDUSKY COUNTIES, OHIO**

OPENING DATE: 2:00 P.M. (E.S.T), FEBRUARY 6, 2015


ALL BIDS MUST BE ELECTRONICALLY SUBMITTED

ATTENTION OF BIDDERS IS DIRECTED TO:

**SPECIAL PROVISIONS
SPECIAL PROVISIONS, Page 115**

ANSWERS TO QUESTIONS RECEIVED THROUGH NOON, FEBRUARY 3, 2015

Issued by the Ohio Turnpike and Infrastructure Commission on February 3, 2015. Issuance authorized by Anthony Yacobucci, Chief Engineer, and Tommie Jo Marsilio, Director, Contracts Administration and Compliance.


Anthony Yacobucci 2/3/15
Date


Tommie Jo Marsilio 2/3/15
Date

**OHIO TURNPIKE AND INFRASTRUCTURE COMMISSION
ADDENDUM NO. 1
PROJECT NO. 59-15-02**

**MODIFICATIONS VIA ADDENDUM NO. 1 TO THE CONTRACT DOCUMENTS FOR
CONTRACT NO. 59-15-02:**

Modifications to the Special Provisions

Deletions are shown with strikethrough text.

Changes/Additions are shown with ***bold italicized*** text.

The following Special Provision page(s) have been revised and the new Special Provision page(s) should be substituted for:

- Page 115

Please note Bids may not be submitted using the Excel Worksheet.

ANSWERS TO QUESTIONS RECEIVED THROUGH NOON, FEBRUARY 3, 2015

Q#1 Regarding the Tack coat for the Longitudinal Joint Repair Ty 1 and 2, is the intent to use Trackless Tack for these items or use the products listed under SP 407?

A#1 For Longitudinal Joint Repairs Type 1 and Type 2, the Contractor shall use Trackless Tack for tack coating all exposed milled surfaces.

Q#2 Will the Material Transfer Device be required to place SP 403?

A#2 A Material Transfer Device will not be required for the placement of SP 403.

Q#3 During Stage 1-Phases 3 & 4, will grinding and paving trucks below allowed to ingress/egress into the closed zone at the point of milling / paving operations OR will the ingress be at the beginning of the zone closure and egress at the end of the zone closures? My scenario is if the milling or and paving location is EB at say MP 78, will trucks have to ingress at MP 73.65 and travel thru the entire closed zone and thru the exit / entrance ramps at Wyandot Plaza before getting to the work area OR can the trucks ingress & egress at MP 78 work area?

A#3 Ingress and egress will be permitted at the Work site provided each location is attended by a flagger, the flagger location is properly illuminated by a light plant, and the ingress/egress operations are continuously performed in a safe manner. Any Contractor proposed ingress and egress locations within the construction zone shall be submitted to the Chief Engineer for review and approval. The ingress and egress locations may be included in the proposed night work plan that is to be submitted in accordance with SP 106.

Addendum No. 1 to is hereby acknowledged:
Contract No. 59-15-02

(Firm Name)

(Signature)

(Printed Name)

Date: _____

SPECIAL PROVISIONS

SP 627

STONE SHOULDER PROTECTION

(11-21-12 2/3/15)

A. Description

The Work shall consist of removing vegetation and other accumulation of debris under the guardrail and the furnishing and placing of stone backfill as shown on the Plans and in accordance with these Special Provisions. The removal, storage and reinstallation of existing mile markers and delineators shall be considered incidental to this Work.

B. Materials

Stone backfill shall be durable No. 67 size carbonate stone, graded in accordance with Section 703.01 of the Specifications.

C. Construction Methods

Existing vegetation and other accumulated debris shall be removed to the dimensions shown on the Plans and replaced with stone backfill material. All material removed shall be disposed of in strict accordance with SP 105 of these Special Provisions. An herbicide shall be applied to the area after final grading and before placement of the stone. The herbicide shall be Treflan EC, Spike or approved equal. Herbicide application shall strictly adhere to the instructions of the manufacturer and applied only by properly licensed personnel as required by the Ohio Revised Code.

D. Method of Measurement and Basis of Payment

Work under Stone Shoulder Protection shall be paid for at the Contract unit price per ~~ton~~ **cubic yard**, furnished, and placed, which price and payment shall be full compensation for excavation; disposal of unsuitable material; furnishing, placing stone backfill; removal, storage and reinstallation of mile markers and delineators; applying herbicide; and all labor, equipment, tools and incidentals necessary to perform the Work, complete and accepted.

Payment shall be made under:

<u>Item</u>	<u>Unit</u>	<u>Description</u>
SP 627	Ton Cu.Yd.	Stone Shoulder Protection