



**OHIO TURNPIKE AND  
INFRASTRUCTURE COMMISSION**

**ADDENDUM NO. 1**  
**ISSUED JUNE 27, 2023**  
**to**  
**BID INVITATION NO. 4436**

**FURNISHING AND INSTALLING A ROOF TOP HVAC UNIT AT TOLL PLAZA 49**

**OPENING DATE: 2:00 P.M. (EASTERN TIME), JULY 6, 2023**

**ATTENTION OF BIDDERS IS DIRECTED TO:**

**ANSWERS TO QUESTIONS RECEIVED THROUGH 3:00 P.M. ON JUNE 27, 2023**

Issued by the Ohio Turnpike and Infrastructure Commission through Aimee W. Lane, Esq., Director of Contracts Administration.

June 27, 2023

Aimee W. Lane, Esq.  
Director of Contracts Administration

ADDENDUM NO. 1  
BID INVITATION NO.4436  
PAGE 2

**ANSWERS TO QUESTIONS RECEIVED THROUGH 3 P.M. ON JUNE 27, 2023:**

**Q#1 On part 7: Specifications, is the LP and Hi Altitude conversion kit required?**

*A#1 These items will be required as the only fuel source for the unit is liquid propane.*

**END OF ADDENDUM NO. 1**