



**OHIO TURNPIKE AND  
INFRASTRUCTURE COMMISSION**

**ADDENDUM NO. 1**  
**ISSUED: MARCH 26, 2025**

**to**

**BID INVITATION NO. 4479**

**OPENING DATE: 2:00 P.M. (EASTERN TIME), APRIL 3, 2025**

**ATTENTION OF BIDDERS IS DIRECTED TO:**

**ANSWERS TO QUESTIONS RECEIVED THROUGH 1:00 P.M. ON MARCH 26, 2025**

Issued by the Ohio Turnpike and Infrastructure Commission through Aimee W. Lane, Esq., Director of Contracts Administration.

*Aimee W. Lane* /kjpg

\_\_\_\_\_  
Aimee W. Lane, Esq.,  
Director of Contracts Administration

March 26, 2025  
Date

**ANSWERS TO QUESTIONS RECEIVED THROUGH 1:00 P.M. ON MARCH 26, 2025:**

- Q#** I wanted to clarify Section 7 Lubrication System: “Engine oil and filters are replace by Commission mechanics annually.”  
I am bidding the inspection portion only. I am not to quote replacing oil and filters. Does the Commission have their own “Commission mechanics” or are we considered the “Commission Mechanic”?
- A#1 Commission mechanics are in-house Ohio Turnpike staff and handle the preventive maintenance for these generators. The inspections do not require the awarded vendor to replace oil or filters.*
- Q#2** What month would you want to start the Maintenance Process and Load banking?
- A#2 The Specifications require the load bank testing to be completed at any time within the first 12 months of the contract. This can be done either at the same time as the annual inspection or separately, if necessary. All scheduling must be coordinated with the Commission's Facility Operations Coordinator.*

**END OF ADDENDUM NO. 1**