



**OHIO TURNPIKE AND
INFRASTRUCTURE COMMISSION**

ADDENDUM NO. 6
ISSUED MAY 21, 2020

PROJECT NO. 58-20-01
NEW MAINLINE TOLL PLAZA FACILITY
UTILITY BUILDINGS, TOLL BOOTHS & CANOPIES
MILEPOST 49
LUCAS COUNTY, OHIO

OPENING DATE: 2:30 ~~2:00~~ P.M. (EASTERN TIME), MAY 27 ~~21~~, 2020
ALL BIDS MUST BE ELECTRONICALLY SUBMITTED

ATTENTION OF BIDDERS IS DIRECTED TO:
ANSWERS TO QUESTIONS RECEIVED THROUGH 1:00 P.M. ON MAY 21, 2020

Issued by the Ohio Turnpike and Infrastructure Commission through Jennifer L. Stueber, Esq., General Counsel.

Jennifer L. Stueber, Esq.,
General Counsel

May 21, 2020
Date

ANSWERS TO QUESTIONS RECEIVED THROUGH 1:00 P.M. ON MAY 21, 2020:

Q#82 Are the Crouse Hinds WJBF specified pull boxes on sheets I118, I119, I121 and I122 and details on I125 sized for sufficient size based on the pathways and stub ups shown on the mentioned plans? These boxes carry an expensive price tag and size is important.

A#82 The pull boxes are adequately sized.

Q#83 Is there a detail showing the stub up locations of the 3" conduits entering the toll booths from the electrical duct banks?

A#83 The electrical conduit shall be stubbed up in the wall cavity directly below the load center. The 3" communication conduits shall be stubbed up 3" AFF under the end cabinet. All conduits must rise within 4" of the wall and 1" within the end wall as indicated in Key Note 2 on Plan Sheet E111.

APPROVED EQUALS CHART:

The following are modifications to the Approved Equals Chart for this Project with the issuance of Addendum No. 6:

| <u>COMPANY NAME</u> | <u>PRODUCT</u> | <u>SPECIFICATION</u> | <u>APPROVAL</u> | <u>Addendum</u> |
|-------------------------------|-------------------------------|-----------------------------|------------------------|------------------------|
| Scranton Products | Hiney Hiders Partitions | 102113.17 | Approved | 1 |
| Scranton Products | Duralife Lockers | 105113 | Not Approved | 1 |
| Stanley Commercial Hardware | Door Closer | 087100 | Approved | 1 |
| Stanley Commercial Hardware | Locks | 087100 | Approved | 1 |
| Control Systems of Ohio | Direct Digital Control System | 230923 | Not Approved | 2 |
| Transtar Electric/ Siemens | Fire Alarm | 284621.11 | Approved | 4 |

**Receipt of Addendum No. 6
Project No. 58-20-01 is hereby acknowledged:**

(Firm Name) _____

(Signature) _____

(Printed Name) _____

(Date) _____

**BIDDERS MUST RETURN THE ABOVE ACKNOWLEDGEMENT
OF RECEIPT OF ADDENDUM NO. 6 WITH THEIR BID.**