



**OHIO TURNPIKE AND
INFRASTRUCTURE COMMISSION**

ADDENDUM NO. 2
ISSUED: MAY 22, 2026

PROJECT NO. 58-26-02

**TOLL PLAZA 161 REMOVAL & REPLACEMENT TOLL BOOTH NO. 1 M.P. 161.8
CUYAHOGA COUNTY, OHIO**

ISSUED MAY 14, 2026

OPENING DATE: 2:00 P.M.(EASTERN TIME) JUNE 4, 2026

ATTENTION OF BIDDERS IS DIRECTED TO:

ANSWERS TO QUESTIONS RECEIVED THROUGH 8:00 A.M. ON MAY 22, 2026

MODIFICATIONS TO THE CONTRACT DOCUMENTS

Specification: 07500 Flexible (EPDM) Sheet Roofing System

Issued by the Ohio Turnpike and Infrastructure Commission through Aimee W. Lane, Esq., Director of Contracts Administration.

Aimee W. Lane

Aimee W. Lane, Esq.,
Director of Contracts Administration

May 22, 2026
Date

ANSWERS TO QUESTIONS RECEIVED THROUGH 8:00 A.M. ON MAY 22, 2026:

- Q#3** After reviewing the roof plans for the Toll Booth Mile Marker 161.8, we notices a discrepancy showing Duro-Last PVC membrane and wall flashings and the listing for EPDM roofing. Please consider removing the EPDM portion. It is not necessary with the PVC system.
- A#3* Specification “07500 Flexible (EPDM) Sheet Roofing System” does not apply to this project, and has been deleted from the Special Provisions.

END OF ADDENDUM NO. 2