



**OHIO TURNPIKE AND  
INFRASTRUCTURE COMMISSION**

**ADDENDUM NO. 4**  
**ISSUED: MARCH 28, 2024**

**PROJECT NO. 59-24-02 & 43-24-02**

**PART A: PROJECT NO. 59-24-02 REPAIRS & RESURFACING EASTBOUND &  
WESTBOUND ROADWAYS M.P. 62.88 TO M.P. 73.95, PART B: PROJECT NO. 43-24-02  
BRIDGE DECK OVERLAY, REPAIR & REHABILITATION OHIO TURNPIKE OVER 1-  
280/SR-420 M.P. 71.4 WOOD COUNTY, OHIO**

**ISSUED MARCH 6, 2024**

**OPENING DATE: 2:30 P.M. (EASTERN TIME) ~~MARCH 27~~, APRIL 3, 2024**

**ATTENTION OF BIDDERS IS DIRECTED TO:**

**ANSWERS TO QUESTIONS RECEIVED THROUGH 8:00 A.M. ON MARCH 28, 2024**

**MODIFICATIONS TO THE CONTRACT DOCUMENTS**

Issued by the Ohio Turnpike and Infrastructure Commission through Aimee W. Lane, Esq., Director of Contracts Administration.

*Aimee W. Lane*

\_\_\_\_\_  
Aimee W. Lane, Esq.,  
Director of Contracts Administration

March 28, 2024  
Date

**ANSWERS TO QUESTIONS RECEIVED THROUGH 8:00 A.M. ON MARCH 28, 2024:**

**Q#14 Addendum #3 added references #92 Curb removed and #93 Aggregate Drains to the Part B contract, should this be included in the Part A work?**

*A#14 For clarification, Bid Ref. Nos. #92 and #93 are intended to be included with Project No. 59-24-02 Part A, which is also shown on Plan Sheet 20 of 21.*

**Q#15 Can clarification be provided for the material to be used for Concrete Waterproofing SP 536 for both the bridge deck and parapet line items.**

*A#15 SP 536 requires that non-Epoxy sealers be utilized on all turnpike mainline bridge decks and parapets and specifies the material performance requirements for absorption, scaling resistance, absorbed chlorides, skid resistance, and allowable volatile organic content. A product that meets specifications shall be submitted for approval during the material submittal process once a contractor has been awarded the project.*

**END OF ADDENDUM NO. 4**