



**OHIO TURNPIKE AND
INFRASTRUCTURE COMMISSION**

ADDENDUM NO. 1
ISSUED FEBRUARY 23, 2023

BID INVITATION NO. 4430

FIRE ALARM SERVICE & INSPECTION

OPENING DATE: 2:00 P.M. (EASTERN TIME), FEBRUARY 27, 2023

ATTENTION OF BIDDERS IS DIRECTED TO:

ANSWERS TO QUESTIONS RECEIVED THROUGH 10:00 A.M. ON FEBRUARY 23, 2023

Issued by the Ohio Turnpike and Infrastructure Commission through Aimee W. Lane, Esq., General Counsel.

Aimee W. Lane
Aimee W. Lane, Esq.
Director of Contracts Administration

February 23, 2023

ANSWERS TO QUESTIONS RECEIVED THROUGH 10:00 A.M. ON FEBRUARY 23, 2023:

Q#1 I am looking at the device counts for sprinklers but does not say if the systems are dry systems or wet systems? Can I please have that information to complete the bid?

A#1 Sprinkler systems that are not listed as an FM-200 System are wet systems. There are 24 Sprinkler systems (wet) and 33 FM-200 chemical systems listed on Schedule A (see Part 5 Bid Form Instructions).

Q#2 Do you have an initiating device count for each buildings fire alarms system?

A#2 A complete count of all devices is not available at this time.

Q#3 The subject bid invitation is for Fire Systems Inspection, Testing, & Repair. This is all Labor and requires no parts/material unless something is not working. If that is the case the needed item could be one of many and we are not able to determine the place of origin or manufacture.

Please advise how we should complete the section of the bid document.

A#3 For purposes of completing Part 12, Ohio Turnpike and Infrastructure Commission, Certificate for Domestic and Ohio Preference Form, please respond using the location(s) from which the bidder will be providing the required services.

END OF ADDENDUM NO. 1