



**OHIO TURNPIKE AND
INFRASTRUCTURE COMMISSION**

ADDENDUM NO. 1
ISSUED: FEBRUARY 16, 2022

PROJECT NO. 59-22-04

**PART A: REPAIRS AND RESURFACING EASTBOUND & WESTBOUND ROADWAYS
MILEPOST 178.05 TO MILEPOST 185.65 PART B: REPAIRS AND RESURFACING
INTERCHANGE 187 RAMPS MILEPOST 187.20 SUMMIT & PORTAGE COUNTIES, OHIO**

OPENING DATE: 2:00 P.M. (EASTERN TIME), FEBRUARY 22, 2022

ATTENTION OF BIDDERS IS DIRECTED TO:

ANSWERS TO QUESTIONS RECEIVED THROUGH 8:00 A.M. ON FEBRUARY 16, 2022

MODIFICATIONS TO THE CONTRACT DOCUMENTS

Notice to Bidders Page 8
-AND-
Special Provision Page SP-2
-AND-
Plan Sheet 1 of 15 (*Project* 59-22-04A)
-AND-
Bid Schedule of Items and Estimated Quantities Worksheet
Reference No.: 13

Issued by the Ohio Turnpike and Infrastructure Commission through Aimee W. Lane, Esq., Director of Contracts Administration.

Aimee W. Lane, Esq.,
Director of Contracts Administration

February 16, 2022
Date

ANSWERS TO QUESTIONS RECEIVED THROUGH 8:00 A.M. ON FEBRUARY 16, 2022:

Q#1 Please review the language included in the Notice to Bidders on page 8 of the bid documents. Under Part A, the description of the project indicates that the inside and outside shoulders as well as the left lane are to be resurfaced at a depth of 2". However the typical sections on page 5 show that only the outside shoulder is scheduled to receive the 2" resurfacing. The plan quantities would seem to match the typical sections as well. Please provide clarification as to which direction the commission intends.

*A#1 The language presented on page 8 of the Notice to Bidder and Special Provision page SP-2 has been reviewed and revised. The language referencing work in the left lane and left shoulder has been removed to match the anticipated Work as shown on the typical section on Plan Sheet 5 of 15 (~~Contract~~ **Project** 59-22-04A). Additionally, Plan Sheet 1 of 15(~~Contract~~ **Project** 59-22-04A) has been reviewed and revised to correct the title and the Index of Sheets. Plan Sheet 1 of 15 (~~Contract~~ **Project** 59-22-04A), page 8 of the Notice to Bidder, and Special Provision page SP-2 are included with this Addendum No. 1.*

Q#2 Please review Ref #13 – Subgrade Compaction. The unit of measure is listed as CY, please update to a SY unit of measure.

*A#2 The bid form has been reviewed and revised. The Units for Reference No. 13, have been revised from ~~CU.YD.~~ to **SQ.YD.** The revised bid form has been included with this Addendum No. 1.*

END OF ADDENDUM NO. 1