



**OHIO TURNPIKE AND
INFRASTRUCTURE COMMISSION**

ADDENDUM NO. 1
ISSUED: JANUARY 4, 2024

To

LOI NO. 19-2023

**REQUEST FOR LETTERS OF INTEREST (LOIs) FOR PROFESSIONAL ENGINEERING
SERVICES PROJECT NO. 71-23-12**

ISSUED: DECEMBER 15, 2023

LETTERS OF INTEREST DUE DATE: 5:00 P.M. (Eastern) JANUARY 12, 2024

ATTENTION OF RESPONDENTS IS DIRECTED TO:

Existing Plans, Bridge Inspection Reports and Photos, Soils Information, and Utility Information
(available upon request as noted herein)

ANSWERS TO QUESTIONS RECEIVED THROUGH 5:00 PM ON JANUARY 3, 2024:

Issued by the Ohio Turnpike and Infrastructure Commission through Aimee W. Lane, Esq., Director of
Contracts Administration

Aimee W. Lane

Aimee W. Lane, Esq.,
Director of Contracts Administration

JANUARY 4, 2024
Date

ANSWERS TO QUESTIONS RECEIVED THROUGH 5:00 P.M. ON JANUARY 3, 2024:

Q#1 Will an asbestos survey or lead paint investigation be required for this project?

A#1 An asbestos survey and evaluation of the protective coating system, including testing of any suspect areas for lead paint, will be required for this project.

Q#2 Will any geotechnical testing of existing concrete be required?

A#2 Geotechnical testing is not anticipated for this project.

Q#3 Is phase construction or full-width construction anticipated for MP 162.2 (Albion Rd) and MP 169.5 (Broadview Rd)? Or is this to be studied and recommended by the selected consultant during the engineering investigation phase?

A#3 A recommendation is to be provided by the selected consultant during the engineering investigation phase.

Q#4 Will the OTIC CAD requirements need to be followed, or will use of the OH State Kit be accepted?

A#4 OTIC has developed new CAD standards that closely match the ODOT State Kit. These new standards should be available when this project reaches the design stage, otherwise the ODOT State Kit is acceptable for use.

Q#5 Will the design requirements follow the ODOT 2020 BDM?

A#5 Design requirements will follow the most recent edition of the ODOT 2020 BDM.

Note: Existing Plans, Bridge Inspection Reports and Photos, Soils Information, and Utilities Information are available upon request to purchasing@ohioturnpike.org and will be sent by email with a File Transfer Portal (FTP) link.

END OF ADDENDUM NO. 1