



**OHIO TURNPIKE AND
INFRASTRUCTURE COMMISSION**

ADDENDUM NO. 2
ISSUED: APRIL 20, 2021

PROJECT NO. 58-21-03

PART A: TOLL PLAZA 64 EXPANSION PLANS, MILEPOST 64.9, WOOD COUNTY, OHIO
PART B: TOLL PLAZA 152.2 EXPANSION PLANS, MILEPOST 152.2, LORAIN COUNTY, OHIO
ISSUED: APRIL 7, 2021

OPENING DATE: 2:00 P.M. (EASTERN TIME), APRIL 28, 2021

ATTENTION OF BIDDERS IS DIRECTED TO:
ANSWERS TO QUESTIONS RECEIVED THROUGH 12:00 P.M. ON APRIL 20, 2021

-AND-

MODIFICATIONS TO THE CONTRACT DOCUMENTS

Specification Sections: Index, 07465, and 07500

Issued by the Ohio Turnpike and Infrastructure Commission through Jennifer L. Stueber, Esq., General Counsel.

Jennifer L. Stueber, Esq.,
General Counsel

April 20, 2021
Date

ANSWERS TO QUESTIONS RECEIVED THROUGH 12:00 P.M. ON APRIL 20, 2021:

Q#3 I am requesting that the Ohio Turnpike Infrastructure Commission revise all future projects that include roofing would allow for mechanically attached in lieu of adhered.

A#3 The request has been reviewed for this Project and an adhered roofing membrane shall be provided as specified in the Plans and Specifications. The following Specifications Sections (Section 07465 and Section 07500), not originally included in the bid documents, provide additional information for the bidders on adhering panels to the canopy. Specification Section 07465 PREFORMED METAL SIDING AND SOFFIT and Specification Section 07500 – FLEXIBLE (EPDM) SHEET ROOFING SYSTEMS are included as part of this Addendum No. 2.

END OF ADDENDUM NO. 2