



**OHIO TURNPIKE AND
INFRASTRUCTURE COMMISSION**

ADDENDUM NO. 2

ISSUED: FEBRUARY 28, 2023

To

LOI NO. 4-2023

**REQUEST FOR LETTERS OF INTEREST (LOIs)
FOR PROFESSIONAL ENGINEERING SERVICES
PROJECT NO. 71-23-05**

ISSUED: FEBRUARY 13, 2023

LETTERS OF INTEREST DUE DATE: 5:00 P.M. (Eastern) MARCH 6, 2023

ATTENTION OF RESPONDENTS IS DIRECTED TO:

ANSWERS TO QUESTIONS RECEIVED THROUGH 5:00 PM ON FEBRUARY 27, 2023:

Issued by the Ohio Turnpike and Infrastructure Commission through Aimee W. Lane, Esq., Director of Contracts Administration

Aimee W. Lane

Aimee W. Lane, Esq.,
Director of Contracts Administration

February 28, 2023
Date

ANSWERS TO QUESTIONS RECEIVED THROUGH 5:00 P.M. ON FEBRUARY 27, 2023:

Q#10 Please confirm if the paint coating thickness testing is part of the scope of work on this project, now that CEI is not part of this contract.

A#10 Per the Appendix A “Draft Scope of Services”, the engineering report shall include an evaluation of the Protective Coating system. This is an evaluation of the existing coating system. Inspection of, if any, Protective Coating System installed as part of future work on the bridges is not part of this contract.

Q#11 What certifications does OTIC require for the person performing this work.

A#11 The consultant shall have persons qualified in the evaluation of the existing Protective Coating system perform this work. Successful completion of one (1) of the following requirements is expected: National Association of Corrosion Engineers (NACE) Certified Coatings Inspector Level 1 Certified, Society for Protective Coatings (SSPC) or Association of Materials Protection and Performance (AMPP) Protective Coatings Inspector Level 1 Certified, and/or Society for Protective Coatings (SSPC) or Association of Materials Protection and Performance (AMPP) Bridge Coating Inspector Level 1.

END OF ADDENDUM NO. 2