OHIO TURNPIKE AND
INFRASTRUCTURE COMMISSION

ADDENDUM NO. 3
ISSUED: MARCH 26, 2024

PROJECT NO. 59-24-02 & 43-24-02

PART A: PROJECT NO. 59-24-02 REPAIRS & RESURFACING EASTBOUND & WESTBOUND ROADWAYS M.P. 62.88 TO M.P. 73.95, PART B: PROJECT NO. 43-24-02 BRIDGE DECK OVERLAY, REPAIR & REHABILITATION OHIO TURNPIKE OVER 1-280/SR-420 M.P. 71.4 WOOD COUNTY, OHIO

ISSUED MARCH 6, 2024

OPENING DATE: 2:30 P.M. (EASTERN TIME) ~~MARCH 27,~~ APRIL 3, 2024

ATTENTION OF BIDDERS IS DIRECTED TO:

ANSWERS TO QUESTIONS RECEIVED THROUGH 8:00 A.M. ON MARCH 26, 2024

MODIFICATIONS TO THE CONTRACT DOCUMENTS

Part A: Project 59-24-02 Plan Sheet 20 of 21
Part B: Project 43-24-02 Plan Sheets: 3 and 4 of 9
-AND-
Bid Schedule of Items and Estimated Quantities Worksheet Reference Nos.: 54 and 79
-AND-
Bid Opening Date to be extended from March 27, 2024, at 2:00 PM until April 3, 2024, at 2:30 PM.

Issued by the Ohio Turnpike and Infrastructure Commission through Jennifer Monty Rieker, Esq., General Counsel.

Jennifer Monty Rieker, Esq.,
General Counsel

March 26, 2024
Date

ANSWERS TO QUESTIONS RECEIVED THROUGH 8:00 A.M. ON MARCH 26, 2024:

Q#12 Would the OTIC consider changing their SP (see below) to allow a cold joint if the face of the joint is sealed with a SP 404A joint sealer?

The SP 404 shall be laid either in full width of the pavement as shown in the Plans or in two (2) parallel lanes.

A#12 The Project shall be bid as specified. The awarded Contractor may bring forward an alternate construction method in which a waiver of the full width surface course paving requirements as called for in the Plans and Specifications can be requested. Any alternate construction methods are subject to review and approval by the OTIC.

Q#13 What items of work does the OTIC believe should be complete under (Ref 79 PORTIONS OF STRUCTURE REMOVED)? We cannot find any removal items on the MP 71.4 structure that would typically be paid under this reference.

A#13 Ref. No. 79 - Item SP 202-Portions of Structure Removed has been removed from the General Summary and Estimated Quantities Worksheet. The Structure General Notes - Sheet 3 of 9, the Estimated Quantities - Sheet 4 of 9, and the Estimated Quantities Worksheet have been updated and provided as part of this Addendum No 3.

Note: The Bid Opening Date has been extended from March 27, 2024, at 2:00 PM until April 3, 2024, at 2:30 PM.

*The plans have been reviewed and revised. Plan Sheet 20 of 21, Item 619 shall read 619, **7.00, MONTH, FIELD OFFICE, TYPE B**. The Estimated Quantity Worksheet Bid Ref. No. 54, the item has been revised to read **FIELD OFFICE, TYPE B, 7.00, MONTH**. Revised Plan Sheet 20 of 21 and the revised Estimated Quantities Worksheet have been included with this Addendum No. 3.*

END OF ADDENDUM NO. 3