



**OHIO TURNPIKE AND  
INFRASTRUCTURE COMMISSION**

**ADDENDUM NO. 2  
ISSUED FEBRUARY 8, 2024**

to

**RFP NO. 2-2024  
FURNISH, INSTALL, MAINTAIN, AND OPERATE ELECTRIC VEHICLE SUPPLY  
EQUIPMENT AT OHIO TURNPIKE SERVICE PLAZAS**

**PROPOSAL DUE DATE: 5:00 P.M. (EASTERN TIME), MARCH 6, 2024**

**ATTENTION OF RESPONDENTS IS DIRECTED TO:**

**ANSWERS TO QUESTIONS RECEIVED THROUGH 5:00 PM ON FEBRUARY 7, 2024**

Issued by the Ohio Turnpike and Infrastructure Commission through Aimee W. Lane, Esq, Director of Contracts Administration.

*Aimee W. Lane*

\_\_\_\_\_  
Aimee W. Lane, Esq.,  
Director of Contracts Administration

February 8, 2024  
Date

**ANSWERS TO QUESTIONS RECEIVED THROUGH 5:00 P.M. ON FEBRUARY 7, 2024:**

**Q#2** There are no panel schedules, electrical one-lines or existing locations of chargers included in the set of drawings provided. These are important to allow us to determine the size and location of transformers and other existing infrastructure. Are we able to get complete sets of electrical drawings for each location?

*A#2 See Electric Vehicle Charging Station plans for specifics on specifications at each Service Plaza.*

- *SP1 – Indian Meadow – Tesla Panel Schedule is located on E-2 (Sheet 15) and sheets 12 to 16 for electrical plans.*
- *SP1 – Indian Meadow – Electrify America – E-1 through E-5 (Sheet 10 to 14)*
- *SP1 – Tiffin River – Tesla Panel Schedule is located on E-2 (Sheet 15) and sheets 12 to 16 for electrical plans.*
- *SP1 – Tiffin River – Electrify America – E-1 through E-5 (Sheet 10 to 14)*
- *SP3 – Blue Heron – Tesla – E-201 to E-501 (Sheet 6 to 7)*
- *SP3 – Blue Heron – Electrify America – E-1 through E-5 (Sheet 10 to 14)*
- *SP3 – Wyandot – Tesla – E-201 to E-501 (Sheet 6 to 7)*
- *SP3 – Wyandot – Electrify America – E-1 through E-5 (Sheet 10 to 14)*
- *SP6 – Great Lakes – Tesla Panel Schedule is located on E-2 (Sheet 16) and sheets 13 to 17 for electrical plans.*
- *SP6 – Towpath – Tesla Panel Schedule is located on E-2 (Sheet 16) and sheets 13 to 17 for electrical plans.*
- *SP8 – Glacier Hills – Tesla Panel Schedule is located on E-2 (Sheet 15) and sheets 12 to 16 for electrical plans.*
- *SP8 – Mahoning Valley - Tesla Panel Schedule is located on E-2 (Sheet 15) and sheets 12 to 16 for electrical plans.*

**Q#3** What are the specifications of the existing Electrify America and Tesla chargers that are in place at each location? Please provide power ratings for existing chargers.

*A#3 See Electric Vehicle Charging Station plans for specifics on specifications at each Service Plaza.*

*Power Ratings:*

- *Indian Meadow, Tiffin River, Blue Heron, and Wyandot Service Plazas*  
*Tesla - (24 Hour) up to 250Kw*  
*Electrify America - (24 Hour) CCS/SAE or CHAdeMO 50kW, 150kW and 350kW*
- *Great Lakes, Towpath, Glacier Hills & Mahoning Valley Service Plazas*  
*Tesla - (24 Hour) up to 250kW*

**Q#4** Will the Ohio Turnpike Authority (OTA) Own and Operate the DCFC Stations or will the company submitting the application be expected to Own & Operate? If Company - will they have to present a lease model to OTA vs a normal proposal?

*A#4 To be answered in a future addendum.*

**Q#5 Is there a preferred software (Ie. Electricity America, EvConnect etc ) that OTA wants spec'd for the project?**

*A#5 To be answered in a future addendum.*

**Q#6 Will OTA allow submissions of 180kW vs 150kW?**

*A#6 To be answered in a future addendum.*

**Q#7 On the current schedule of locations - are we to rip and replace current DCFC or is this incremental?**

*A#7 To be answered in a future addendum.*

**Q#8 Has OTA assessed that the utility can provide power for (4) 150kW DCFC?**

*A#8 To be answered in a future addendum.*

**Q#9 What is the current (A) needed per connector CCS1? Output voltage clear, can they clarify the current?**

*A#9 To be answered in a future addendum.*

**Q#10 About connectors, if they are asking for CCS1, can they suggest HW ready for NACS for possible retrofit in the future?**

*A#10 To be answered in a future addendum.*

**Q#11 POS ( Point of Service) needed? Which integration: Cloud to cloud ( by backend development) or locally by HW? Any specific POS manufacturer?**

*A#11 To be answered in a future addendum.*

**REMINDER:** As stated on page 2 of the RFP: "Copies of existing EVSE plans at the various Service Plazas may be requested pursuant to Section 149.43 of the Ohio Revised Code via [recordsrequest@ohioturnpike.org](mailto:recordsrequest@ohioturnpike.org)."

**END OF ADDENDUM NO. 2**